

RCD/MCB, 10A, 100mA, miniature circuit-breaker trip curve: C, 1pole+N, residual current circuit-breaker trip characteristic: A



Part no. Catalog No. CKN6-10/1N/C/01-A-DE 241331

Similar to illustration

Design verification as per IEC/EN 61439 Technical data for design verification 10 Rated operational current for specified heat dissipation I_n А Heat dissipation per pole, current-dependent P_{vid} w 0 Equipment heat dissipation, current-dependent Pvid w 2.3 Static heat dissipation, non-current-dependent P_{vs} W 0 Heat dissipation capacity W 0 Pdiss °C Operating ambient temperature min. -25 Operating ambient temperature max. °C 40 IEC/EN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 5.0

Circuit breakers and fuses (EG000020) / Earth leakage circuit breaker (EC000905) Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / MCB/RCCB combination (ecl@ss8-27-14-22-07 [AFZ810011]) Number of poles (total) 2 1 Number of protected poles Rated voltage v 230 Rated current А 10 Rated fault current A 0.1 Leakage current type А

Current limiting class		3
Rated short-circuit breaking capacity EN 60898	kA	6
Rated short-circuit breaking capacity IEC 60947-2	kA	0
Frequency		50 Hz
Release characteristic		C
Concurrently switching N-neutral		Yes
Over voltage category		3
Pollution degree		2
Width in number of modular spacings		2
Built-in depth	mm	69.5
Degree of protection (IP)		IP20